

CERTIFICATE

Issued to:
Applicant:
American Power Conversion (A.P.C.) B.V.
Lot 1 Block 5 Phase 2
4106 Cavite, Philippines

Manufacturer/Licensee:
American Power Conversion (A.P.C.) B.V.
Lot 1 Block 5 Phase 2
4106 Cavite, Philippines

Products : Multiple portable socket outlets with SPD
Trade name : APC
Types : PH6....-UK, PF8....-UK

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard BS 1363-2:1995 + A1:1997 + A2:2003 + A3:2007
BS 5733:1995; EN 61643-11:2002 + A11:2007
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2154842

DEKRA hereby grants the right to use the KEMA-KEUR BS1363 certification mark.

The KEMA-KEUR BS1363 certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR BS1363 certification agreement and under the conditions of the KEMA-KEUR BS1363 certification agreement.

This certificate is issued on: 22 August 2012 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2154842.11

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

| | | |
|-------------------------------------|---|---|
| product | : | Multiple portable socket outlets with SPD |
| trade name | : | APC |
| types | : | PF8.....-UK, PH6.....-UK |
| rated current | : | 13 A |
| rated voltage | : | 250 V~ |
| Surge Protective Device | : | |
| SPD design topology | : | voltage limiting/switching |
| SPD type | : | CLASS III |
| Uoc | : | 6 kV |
| Voltage protection level Up | : | 1,4 kV |
| short circuit withstand current Isc | : | 1,5 kA |
| location | : | indoor |
| accessibility | : | inaccessible |
| SPD disconnecter | : | internal |
| protection function | : | thermal |
| earthing | : | with earthing-contacts |
| design | : | non-rewirable, 6 or 8-fold |
| applied flexible cord | : | H05VV-F 3G1,25 and 3G1,5 mm ² |
| certification mark | : | KEMA-KEUR |
| cord termination | : | soldered connection |
| description | : | body of thermoplastic material, provided with a two-pole rocker switch and incorporated Surge Protective Device |
| markings | : | are shown on the body |

Additional information

Structure code table:

PF.....-..
A B C D

A= Type reference PF or PH
B= Number of socket outlet (6, 8)
C= N - Network connection
 V - Video (antenna)
 T - Telephone connection
 3 - Number of telephone or network outputs
D= Country code (UK)

TESTS**Test requirements**

EN 61643-11:2002+A11:2007
BS 1363-2:1995+A1:1997+A2:2003+A3:2007
BS 5733:1995

Test result

The test results are laid down in DEKRA test file 2154842.11.

Remarks

The products specified in this certificate comply with the above-mentioned standards solely for use those countries where the above mentioned standards applies.

This certificate supersedes the previous certificate 2144990.01 issued May 17, 2011.

Conclusion

The examination proved that all test requirements were met.

Tested by : G.H. Reynaert

Checked by : E. Stoel

**Factory locations**

International Precision Assemblies Inc. Plant 3
Lot 9, Block 3, 4106, Rosario Cavite
Philippines

Dongguan Quan Sheng Electric Co., Ltd.
Ju-Tang 2nd Industrial Park, 523963, Dongguan, Guangdong
China

List of components

| Component | trade name | type/model | approval mark ¹⁾ |
|----------------|---------------------|-----------------|-----------------------------|
| MOV | Centra Science Corp | 20D471K | VDE |
| MOV | CERAMATE | GNR20D471KKA | VDE |
| thermal fuse | NEC | SF139U-1 | * |
| thermal fuse | FUJI | FTF412 | * |
| gas tube | CERAMATE | 80A600L | * |
| AC plug | DC | DC-168A | ASTA |
| AC plug | MEC | UK-301 / UK-302 | KEMA-KEUR |
| AC plug | Ningbo Qiaopu | D09 | INTERTEK |
| rocker switch | Merchant | SR-06NR | ENEC |
| rocker switch | Canal | MR series | VDE |
| flexible cable | any type | H05VV-F | KEMA-KEUR |

¹⁾ * indicates a component tested as part of the appliance